

Garrey W. Curry, Jr.
County Administrator



Christine Smith, Chair
Debbie P. Donehey, Vice-Chair
Ronald L. Frazier
I. Christopher Parrish
Keir A. Whitson

**RAPPAHANNOCK COUNTY
BOARD OF SUPERVISORS**

3 Library Road - P.O. Box 519
Washington, Virginia 22747-0519
Phone: (540) 675-5330 Fax: (540) 675-5331
www.rappahannockcountyva.gov

**RAPPAHANNOCK COUNTY BOARD OF SUPERVISORS
SOLICITATION FOR BIDS
Invitation For Bid #20-03GWC
“Sperryville Tower Civil and Electrical”**

2/25/2020

ADDENDUM #1:

- Plan Sheet C-1 & E-4 (Handhole Detail), The horizontal dimensions of the handhole shall be 24-inches square (nominal).
- Plan Sheet C-1 & C-4 (Ice Bridge details), The ice bridge may be 12-inches wide or 24-inches wide at the discretion of the contractor based on available stock.
- Plan Sheet C-1, Delete General Note 1 and Replace with:
“1. Owner to provide proposed generator (Kohler Model 25CCL), ATS and Surge Protection Device. Owner expects the ATS and Surge Protection Device to ship to the site and be ready for Contractor unloading and installation in advance of the generator. Contractor shall make all efforts to install owner and contractor provided materials and equipment making a complete system except for the generator with the expectation that the generator will be the last piece of equipment that will arrive at the site. Contractor shall coordinate as necessary to accommodate an Owner provided rental generator to allow the site to become active using the installed ATS and then install the Owner provided generator when it arrives at the site.”
- Plan Sheets, Contrary to the notes included on the Plan Sheets, Contractor shall provide and install the necessary electrical disconnect switch

END ADDENDUM #1