

Garrey W. Curry, Jr.
County Administrator



Christine Smith, Chair
Debbie P. Donehey, Vice-Chair
Ronald L. Frazier
I. Christopher Parrish
Keir A. Whitson

**RAPPAHANNOCK COUNTY
BOARD OF SUPERVISORS**

3 Library Road - P.O. Box 519
Washington, Virginia 22747-0519
Phone: (540) 675-5330 Fax: (540) 675-5331
www.rappahannockcountyva.gov

**RAPPAHANNOCK COUNTY BOARD OF SUPERVISORS
SOLICITATION FOR BIDS
Invitation For Bid #20-02GWC
“County Offices Electrical Upgrades”**

3/16/2020

ADDENDUM #1:

A1-1) Plan Sheet E2, Power Demolition Plan Notes: Change introductory note as follows:

“All receptacles shown light with (E) next to them shall remain and function as before. All receptacles shown dark shall ~~be replaced~~ remain. ~~with~~ New red color devices shall be installed and connected to the new circuit number shown on sheet E3.”

A1-2) Plan Sheet E2, Power Demolition Plan Notes: Change diamond note #4 as follows:

“~~Disconnect~~ Retain receptacles shown in the space and install new circuits immediately adjacent with red color devices connected to panel U as shown on sheet E3. ~~from circuit wiring and remove back to source. Maintain continuity to other receptacles on the same circuit. Turn off and mark unused breakers as spare.~~”

A1-3) Plan Sheet E3 (First Floor Power New Work Plan): Eliminate from the new work plan the devices identified to be installed at 84” above fixed floor. Existing devices at 84” above fixed floor will remain.

A1-4) Plan Sheet E3 (Basement Power New Work Plan): Conduits required between generator and new work (New work notes 2a, 2b, 2c, 2d) route through an area congested with underground conduits (existing electric and data) and must be hand dug.

A1-5) Owner provided equipment as referenced on plans includes:

- Generator – Kohler Model KG60
- 400 amp ATS – ASCO SER ATS in NEMA 3R cabinet
- 800 amp ATS – ASCO SER ATS in NEMA 3R cabinet
- UPS – Liebert Model AS6D0NCJHNNX043 rated at 20 kVA with NMBHW81 wall mounted Maintenance Bypass Switch
- SPD – ASCO Model 460

END ADDENDUM #1